3800-FM-BCW0436 10/2017



COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION **BUREAU OF CLEAN WATER**

Facility N Municipa Watersh	lame: <u>U. S. Steel Fairless Hills Facility</u> lity: <u>Falls Township</u> ed: <u>2-E</u>			Co	ounty: <u>Bucks</u>		Month: Year: NPDES Permit No.: <u>PA0013463</u> Renewal application due <u>180 days</u> prior to expiration This permit will expire on <u>November 30, 2026</u>			
Day	Influent					Process Control				
	Flow (MGD)	BOD5 (mg/l)	BOD5 (lbs)	TSS (mg/l)	TSS (lbs)	Aeration MLSS (mg/l)	Aeration DO (mg/l)	Sludge Wasted (gallons)	[FORMTEXT]	[FORMTEXT]
1										
2										
3 4										
5										
6										
7										
8										
9 10										
11						1				
12										
13										
14										
15 16										
17										
18										
19										
20										
21 22										
23				-						
24										
25										
26										
27										
28										
29 30						_				
31										
Avg		***************************************								
Max										
informat best of r	ion submitted. ny knowledge	Based on my and belief, true ee 18 Pa. C.S.	inquiry of the pe	erson or persons	who manage the ware that there a	system or those person	s directly responsible for	d to assure that qualified or gathering the informa rmation, including the po	tion, the information sub	mitted is, to the

3800-FM-BCW0436 10/2017 Instructions



COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION BUREAU OF CLEAN WATER

INSTRUCTIONS FOR COMPLETING INFLUENT & PROCESS CONTROL SUPPLEMENTAL REPORT

- 1. Enter Facility Name, Municipality, County, Watershed No., Month, Year, NPDES Permit No., and Permit Expiration Date.
- 2. For **Influent**, enter daily average <u>Influent</u> Flow (MGD) (if an influent flow meter is in use), daily influent BOD₅ or BOD₅ concentrations (mg/l) and loads (lbs), and daily influent TSS concentrations (mg/l) and loads (lbs). Calculate loads by multiplying daily average flow (MGD) by daily average concentration (mg/l) and a conversion factor of 8.34. If an influent flow meter is not in use, you may use results from an effluent flow meter.
- 3. For Process Control, enter daily average Mixed Liquor Suspended Solids (MLSS) (mg/l) and daily average Aeration Dissolved Oxygen (DO) for aerobic biological treatment systems, and total daily Sludge Wasted (removed from biological treatment), in gallons, for all treatment system types. If a parameter does not apply to your facility, leave the column blank. Information for other parameters such as Return Activated Sludge (RAS) Rate, Recirculation Rate (for fixed media treatment systems), Sludge Blanket Thickness, Sludge Volume Index, and others may be requested by the DEP office that issued the permit.
- 4. Type the name of the person who prepared the form, the person's job title, and sign and date the form after reading the certification statement.